



Town of Chapel Hill

Town Hall, 2202 Unionville Road, P.O. Box 157,

Chapel Hill, TN 37034

Phone (931) 364-7632 Fax (931) 364-3436

RECEIVED

FEB 06 2015

ENVIRONMENTAL FIELD OFFICE
COLUMBIA

Established 1808

February 3, 2015

The influent meter at sewer plant is broken and not reading flow. I am waiting on the Board of Alderman to approve the purchase of a replacement.

Morningside lift station is broken and we are rebuilding entire lift station. We have 6" bypass pump pumping sewer. It will be 6-8 weeks for all new parts to arrive.

Jon Helmick
Sewer Department Manager